

Zone Temperature Report for VAV TOP Floor STD

Project Name: Multi-Story Office Building
 Prepared by: Carrier Corporation

08/27/2002
 03:00PM

1. Zone Temperature Statistics

	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Occ	Unocc	Unocc	Unocc	Unocc
Zone Name	Max Zone Temp (°F)	Hours > 5.0 °F Above Throt. Range	Hours 0 to 5.0 °F Above Throt. Range	Cooling Setpoint plus Throt. Range (°F)	Hours Within Throt. Range or Dead-band	Heating Setpoint minus Throt. Range (°F)	Hours 0 to 5.0 °F Below Throt. Range	Hours > 5.0 °F Below Throt. Range	Min Zone Temp (°F)	Max Zone Temp (°F)	Cooling Setpoint plus Throt. Range (°F)	Heating Setpoint minus Throt. Range (°F)	Min Zone Temp (°F)
Core and Bath Rooms	77.7	0	0	78.0	7410	67.0	0	0	69.7	82.7	88.0	57.0	71.0
North Modules	77.6	0	0	78.0	7387	67.0	23	0	64.6	84.0	88.0	57.0	58.9
East Modules	77.9	0	0	78.0	7387	67.0	23	0	64.6	86.8	88.0	57.0	58.9
South Modules	77.3	0	0	78.0	7395	67.0	15	0	65.0	85.0	88.0	57.0	59.1
West Modules	77.5	0	0	78.0	7386	67.0	24	0	64.5	87.7	88.0	57.0	59.0
N.E. Corner	77.8	0	0	78.0	7398	67.0	12	0	65.1	90.8	88.0	57.0	58.5
S.E. Corner	77.5	0	0	78.0	7402	67.0	8	0	65.3	91.7	88.0	57.0	58.6
S.W. Corner	77.3	0	0	78.0	7402	67.0	8	0	65.2	92.6	88.0	57.0	58.6
N.W. Corner	77.4	0	0	78.0	7398	67.0	12	0	64.9	91.6	88.0	57.0	58.6
Conference Room	76.2	0	0	78.0	7410	67.0	0	0	67.6	77.9	88.0	57.0	66.1